

EUROMAP 84.5	OPC UA interfaces for plastics and rubber machinery – Extrusion – Part 5: Melt pump
---------------------	--

Release 1.00, 2020-06-01

<p>EUROMAP 84.5 (Release 1.00) is identical with OPC 40084-5 (Release 1.00) and VDMA 40084-5:2020-06</p>

Contents

	Page
Foreword.....	6
1 Scope	6
2 Normative references	6
3 Terms, definitions and conventions	7
3.1 Overview	7
3.2 Conventions used in this document.....	7
3.3 Abbreviations	7
4 General information to OPC UA interfaces for plastics and rubber machinery and OPC UA	8
5 Use cases	8
6 Basic security requirements.....	8
6.1 Application Security	8
6.2 User security/Access control	8
7 MeltPump_InterfaceType	9
7.1 MeltPump_InterfaceType Definition	9
7.2 DeviceClass.....	9
7.3 MeltPressures	9
7.4 Drive	10
7.5 FeedRate	10
7.6 TemperatureZones	10
7.7 SwitchDevice.....	10
8 Profiles and Conformance Units	10
9 Namespaces	10
9.1 Namespace Metadata	10
9.2 Handling of OPC UA Namespaces	11
Annex A (normative) OPC 40084-5 Namespace and mappings.....	13

Figures

Figure 1 – MeltPump_InterfaceType Overview	9
--	---

Tables

Table 1 – MeltPump_InterfaceType Definition	9
Table 2 – Profile URIs for OPC 40084-5	10
Table 3 – OPC 40084-5 Basic Server Facet Definition	10
Table 4 – OPC 40084-5 ProductionDatasetManagement Server Facet Definition	10
Table 5 – NamespaceMetadata Object for this Specification	11
Table 6 – Namespaces used in an OPC 40084-5 Server	11
Table 7 – Namespaces used in this specification	12

OPC Foundation / EUROMAP

AGREEMENT OF USE

COPYRIGHT RESTRICTIONS

- This document is provided "as is" by the OPC Foundation and EUROMAP.
- Right of use for this specification is restricted to this specification and does not grant rights of use for referred documents.
- Right of use for this specification will be granted without cost.
- This document may be distributed through computer systems, printed or copied as long as the content remains unchanged and the document is not modified.
- OPC Foundation and EUROMAP do not guarantee usability for any purpose and shall not be made liable for any case using the content of this document.
- The user of the document agrees to indemnify OPC Foundation and EUROMAP and their officers, directors and agents harmless from all demands, claims, actions, losses, damages (including damages from personal injuries), costs and expenses (including attorneys' fees) which are in any way related to activities associated with its use of content from this specification.
- The document shall not be used in conjunction with company advertising, shall not be sold or licensed to any party.
- The intellectual property and copyright is solely owned by the OPC Foundation and EUROMAP.

PATENTS

The attention of adopters is directed to the possibility that compliance with or adoption of OPC or EUROMAP specifications may require use of an invention covered by patent rights. OPC Foundation or EUROMAP shall not be responsible for identifying patents for which a license may be required by any OPC or EUROMAP specification, or for conducting legal inquiries into the legal validity or scope of those patents that are brought to its attention. OPC or EUROMAP specifications are prospective and advisory only. Prospective users are responsible for protecting themselves against liability for infringement of patents.

WARRANTY AND LIABILITY DISCLAIMERS

WHILE THIS PUBLICATION IS BELIEVED TO BE ACCURATE, IT IS PROVIDED "AS IS" AND MAY CONTAIN ERRORS OR MISPRINTS. THE OPC FOUNDATION NOR EUROMAP MAKES NO WARRANTY OF ANY KIND, EXPRESSED OR IMPLIED, WITH REGARD TO THIS PUBLICATION, INCLUDING BUT NOT LIMITED TO ANY WARRANTY OF TITLE OR OWNERSHIP, IMPLIED WARRANTY OF MERCHANTABILITY OR WARRANTY OF FITNESS FOR A PARTICULAR PURPOSE OR USE. IN NO EVENT SHALL THE OPC FOUNDATION NOR EUROMAP BE LIABLE FOR ERRORS CONTAINED HEREIN OR FOR DIRECT, INDIRECT, INCIDENTAL, SPECIAL, CONSEQUENTIAL, RELIANCE OR COVER DAMAGES, INCLUDING LOSS OF PROFITS, REVENUE, DATA OR USE, INCURRED BY ANY USER OR ANY THIRD PARTY IN CONNECTION WITH THE FURNISHING, PERFORMANCE, OR USE OF THIS MATERIAL, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGES.

The entire risk as to the quality and performance of software developed using this specification is borne by you.

RESTRICTED RIGHTS LEGEND

This Specification is provided with Restricted Rights. Use, duplication or disclosure by the U.S. government is subject to restrictions as set forth in (a) this Agreement pursuant to DFARs 227.7202-3(a); (b) subparagraph (c)(1)(i) of the Rights in Technical Data and Computer Software clause at DFARs 252.227-7013; or (c) the Commercial Computer Software Restricted Rights clause at FAR 52.227-19 subdivision (c)(1) and (2), as applicable. Contractor / manufacturer are the OPC Foundation, 16101 N. 82nd Street, Suite 3B, Scottsdale, AZ, 85260-1830

COMPLIANCE

The combination of EUROMAP and OPC Foundation shall at all times be the sole entities that may authorize developers, suppliers and sellers of hardware and software to use certification marks, trademarks or other special designations to indicate compliance with these materials as specified within this document. Products developed using this specification may claim compliance or conformance with this specification if and only if the software satisfactorily meets the certification requirements set by EUROMAP or the OPC Foundation. Products that do not meet these requirements may claim only that the product was based on this specification and must not claim compliance or conformance with this specification.

TRADEMARKS

Most computer and software brand names have trademarks or registered trademarks. The individual trademarks have not been listed here.

GENERAL PROVISIONS

Should any provision of this Agreement be held to be void, invalid, unenforceable or illegal by a court, the validity and enforceability of the other provisions shall not be affected thereby.

This Agreement shall be governed by and construed under the laws of Germany.

This Agreement embodies the entire understanding between the parties with respect to, and supersedes any prior understanding or agreement (oral or written) relating to, this specification.

Foreword

This specification was created by a joint working group of the OPC Foundation and EUROMAP. It is adopted identically as VDMA Specification.

EUROMAP

EUROMAP is the European umbrella association of the plastics and rubber machinery industry which accounts for annual sales of around 13.5 billion euro and a 40 per cent share of worldwide production. Almost 75 per cent of its European output is shipped to worldwide destinations. With global exports of 10.0 billion euro, EUROMAP's around 1,000 machinery manufacturers are market leaders with nearly half of all machines sold being supplied by EUROMAP members.

EUROMAP provides technical recommendations for plastics and rubber machines. In addition to standards for machine descriptions, dimensions and energy measurement, interfaces between machines feature prominently. The provision of manufacturer independent interfaces ensures high levels of machine compatibility.

OPC Foundation

OPC is the interoperability standard for the secure and reliable exchange of data and information in the industrial automation space and in other industries. It is platform independent and ensures the seamless flow of information among devices from multiple vendors. The OPC Foundation is responsible for the development and maintenance of this standard.

OPC UA is a platform independent service-oriented architecture that integrates all the functionality of the individual OPC Classic specifications into one extensible framework. This multi-layered approach accomplishes the original design specification goals of:

- Platform independence: from an embedded microcontroller to cloud-based infrastructure
- Secure: encryption, authentication, authorization and auditing
- Extensible: ability to add new features including transports without affecting existing applications
- Comprehensive information modelling capabilities: for defining any model from simple to complex

1 Scope

OPC 40084-5 describes the data exchange interface for melt pumps as part of an extrusion line. The interface is used by

- MES (Manufacturing Execution System) for collecting the information generated by extrusion lines at a central point for easier quality assurance and job and dataset management.
- Line controllers to monitor and set process parameters.

Safety related signals like emergency stop are not included.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies

OPC 10000-1, *OPC Unified Architecture - Part 1: Overview and Concepts*

<http://www.opcfoundation.org/UA/Part1/>

OPC 10000-2, *OPC Unified Architecture - Part 2: Security Model*

<http://www.opcfoundation.org/UA/Part2/>

OPC 10000-3, *OPC Unified Architecture - Part 3: Address Space Model*

<http://www.opcfoundation.org/UA/Part3/>

OPC 10000-4, *OPC Unified Architecture - Part 4: Services*

<http://www.opcfoundation.org/UA/Part4/>

OPC 10000-5, *OPC Unified Architecture - Part 5: Information Model*

<http://www.opcfoundation.org/UA/Part5/>

OPC 10000-6, *OPC Unified Architecture - Part 6: Mappings*

<http://www.opcfoundation.org/UA/Part6/>

OPC 10000-7, *OPC Unified Architecture - Part 7: Profiles*

<http://www.opcfoundation.org/UA/Part7/>

OPC 10000-8, *OPC Unified Architecture - Part 8: Data Access*

<http://www.opcfoundation.org/UA/Part8/>

OPC 10000-9, *OPC Unified Architecture - Part 9: Alarms and Conditions*

<http://www.opcfoundation.org/UA/Part9/>

OPC 10000-11, *OPC Unified Architecture - Part 11: Historical Access*

<http://www.opcfoundation.org/UA/Part11/>

OPC 10001-1, *OPC Unified Architecture V1.04 - Amendment 1: AnalogItem Types*

<http://www.opcfoundation.org/UA/Amendment1/>

OPC 10001-3, *OPC Unified Architecture V1.04 - Amendment 3: Method Metadata*

<http://www.opcfoundation.org/UA/Amendment3/>

OPC 10000-100, *OPC Unified Architecture - Part 100: Devices*

<http://www.opcfoundation.org/UA/Part100/>

OPC 40083: OPC UA interfaces for plastics and rubber machinery – General Type definitions (version 1.02)

<http://www.opcfoundation.org/UA/PlasticsRubber/GeneralTypes>

OPC 40084-1: OPC UA interfaces for plastics and rubber machinery – Extrusion – Part 1: General Type Definitions (version 1.0)

<http://www.opcfoundation.org/UA/PlasticsRubber/Extrusion/GeneralTypes/>

3 Terms, definitions and conventions

3.1 Overview

It is assumed that basic concepts of OPC UA information modelling are understood in this specification. This specification will use these concepts to describe the OPC 40084-5 Information Model. For the purposes of this document, the terms and definitions given in the documents referenced in Clause 2 apply.

Note that OPC UA terms and terms defined in this specification are *italicized* in the specification.

3.2 Conventions used in this document

The conventions described in OPC 40083 apply.

3.3 Abbreviations

MES Manufacturing Execution System

4 General information to OPC UA interfaces for plastics and rubber machinery and OPC UA

For general information on OPC UA interfaces for plastics and rubber machinery and OPC UA see OPC 40083.

5 Use cases

OPC 40084-5 describes the data exchange interface for melt pumps as part of an extrusion line. The interface is used by

- MES (Manufacturing Execution System) for collecting the information generated by extrusion lines at a central point for easier quality assurance and job and dataset management.
- Line controllers to monitor and set process parameters.

6 Basic security requirements

6.1 Application Security

For the communication between melt pumps and MES the OPC UA application authentication via X509 certificates shall be used. OPC UA provides functionalities for using self-signed certificates that have to be manually added to a “trust list” as well as for certificates issued by a certificate authority (CA).

The minimum requirements of the protocol level for a OPC 40084-5 compliant connection are:

- Use of (self-signed) certificates for OPC UA application authentication
- Security Policy: Basic256
- Message Security Mode: sign

NOTE: It is not fixed by this specification if the certificate includes a fixed IP address and/or the host name. However, if the certificate includes a host name, a DNS server is expected to resolve the host name. An OPC UA GDS (Global Discovery Server) can be used to manage the connections and certificates.

6.2 User security/Access control

6.2.1 On melt pump

On the melt pump authentication via user name and password is commonly used.

6.2.2 On MES

For the users and roles of the connection the following applies:

- User names can be manufacturer dependent.
- Standard roles are
 - “OPC40084”: read and write access for selected parameters
 - “OPC40084_read_only”: no writing permissions
- Manufacturers can add additional roles. They may not start with “OPC40084”. For these roles, more parameters can be writeable than for the OPC40084 role.
- The standard user “OPC40084” has the role “OPC40084” (and no other additional role), “OPC4004_read_only” has the role “OPC40084_read_only” (and no other additional role); the passwords for the standard users are defined by the manufacturers (they may be empty).

NOTE: OPC UA also allow an anonymous-token (e.g. for testing)

7 MeltPump_InterfaceType

7.1 MeltPump_InterfaceType Definition

This OPC UA *ObjectType* is used for the root *Object* representing a melt pump as part of an extrusion line. It is based on the *ExtrusionDeviceType* (defined in OPC 40084-1) and formally defined in Table 1.

The instance(s) of *MeltPump_InterfaceType* shall be located under the *DeviceSet* *Object* of the Server (see OPC UA Part 100).

NOTE: If the OPC UA server is implemented in the control of the melt pump so only one instance of *MeltPump_InterfaceType* will be created. But it is also possible that one OPC UA server is connected to several machine controls as one interface to the MES. In this case several instances of *MeltPump_InterfaceType* will be created.




Figure 1 – MeltPump_InterfaceType Overview

Table 1 – MeltPump_InterfaceType Definition

Attribute	Value				
BrowseName	MeltPump_InterfaceType				
IsAbstract	False				
References	Node Class	BrowseName	DataType	TypeDefinition	Other
Subtype of 4:ExtrusionDeviceType (defined in OPC 40084-1)					
0:HasComponent	Object	MeltPressures		3:MeasuringDevicesType	M
0:HasComponent	Object	Drive		3:DriveType	M
0:HasComponent	Variable	FeedRate	0:Double	0:AnalogUnitType	O, RO
0:HasComponent	Object	TemperatureZones		4:ExtrusionTemperatureZonesType	O

The *BrowseName* of the object instance shall be "MeltPump_<Manufacturer>_<SerialNumber>"

Example: "MeltPump_Weber_0123456".

7.2 DeviceClass

The *DeviceClass* *Property* in the *MachineInformation* *Object* inside the *ExtrusionDeviceType* shall have the value "Melt pump".

7.3 MeltPressures

This *Object* represents the pressures in the melt. The *MeasuringDevicesType* is defined in OPC 40083.

When instances for melt pressures are created, the *BrowseNames* shall be "MeltPressure_<Nr>" where <Nr> is a three-digit number with leading zeros, starting with "001".

The pressure of the melt shall be delivered in bar or lbf/in² (=psi).

7.4 Drive

This object gives information about the drive of the melt pump. The *DriveType* is defined in OPC 40083.

7.5 FeedRate

This *Variable* represents the volume of the fed material per revolution (e.g. in cm³).

7.6 TemperatureZones

This *Object* is a container for the temperature zones of the melt pump. The *ExtrusionTemperatureZonesType* is defined in OPC 40084-1.

7.7 SwitchDevice

This *Object* is used to switching the melt pump on and off via the interface. The *SwitchDeviceType* is defined in OPC 40083.

8 Profiles and Conformance Units

This chapter defines the corresponding profiles and conformance units for the OPC UA Information Model for OPC 40084-5. *Profiles* are named groupings of conformance units. Facets are profiles that will be combined with other *Profiles* to define the complete functionality of an OPC UA *Server* or *Client*. The following tables specify the facets available for *Servers* that implement the OPC 40084-5 Information Model companion specification.

NOTE: The names of the supported profiles are available in the *Server Object* under *ServerCapabilities.ServerProfileArray*

Table 2 lists all Profiles defined in this document and defines their URIs.

Table 2 – Profile URIs for OPC 40084-5

Profile	URI
OPC 40084-5 Basic Server Profile	http://opcfoundation.org/UA-Profile/PlasticsRubber/Extrusion/MeltPump/Server/Basic
OPC 40084-5 ProductionDatasetManagement Server Facet	http://opcfoundation.org/UA-Profile/PlasticsRubber/Extrusion/MeltPump/Server/ProductionDatasetManagement

Table 3 – OPC 40084-5 Basic Server Facet Definition

Conformance Unit	Description	Optional/ Mandatory
OPC 40084-5 Basic	Support of <i>MeltPump_InterfaceType</i> and all mandatory child elements giving information on the melt pump itself and its components.	M
Profile		
ComplexType Server Facet (defined in OPC UA Part 7)		M
Standard Event Subscription Server Facet (defined in OPC UA Part 7)		M
Method Server Facet (defined in OPC UA Part 7)		M
BaseDevice_Server_Facet (defined in OPC UA Part 100)		M

Table 4 – OPC 40084-5 ProductionDatasetManagement Server Facet Definition

Conformance Unit	Description	Optional/ Mandatory
OPC 40084-5 ProductionDatasetManagement	Support of <i>ProductionDatasetManagementType</i> (defined in OPC 40083) for the management and transfer of recipes (= production datasets) between MES and melt pump	M

9 Namespaces

9.1 Namespace Metadata

Table 5 defines the namespace metadata for this specification. The *Object* is used to provide version information for the namespace and an indication about static *Nodes*. Static *Nodes* are identical for all *Attributes* in all *Servers*, including the *Value Attribute*. See Part5 for more details.

The information is provided as *Object* of type *NamespaceMetadataType*. This *Object* is a component of the *Namespaces Object* that is part of the *Server Object*. The *NamespaceMetadataType ObjectType* and its *Properties* are defined in Part 5.

The version information is also provided as part of the *ModelTableEntry* in the *UANodeSet XML* file. The *UANodeSet XML* schema is defined in Part 6.

Table 5 – NamespaceMetadata Object for this Specification

Attribute		Value	
BrowseName		http://opcfoundation.org/UA/PlasticsRubber/Extrusion/MeltPump/	
References	BrowseName	DataType	Value
HasProperty	NamespaceUri	String	http://opcfoundation.org/UA/PlasticsRubber/Extrusion/MeltPump/
HasProperty	NamespaceVersion	String	1.00
HasProperty	NamespacePublicationDate	DateTime	2020-06-01 00:00:00
HasProperty	IsNamespaceSubset	Boolean	False
HasProperty	StaticNodeIdTypes	IdType[]	{Numeric}
HasProperty	StaticNumericNodeIdRange	NumericRange[]	Null
HasProperty	StaticStringNodeIdPattern	String	Null

9.2 Handling of OPC UA Namespaces

Namespaces are used by OPC UA to create unique identifiers across different naming authorities. The *Attributes NodeId* and *BrowseName* are identifiers. A *Node* in the UA *AddressSpace* is unambiguously identified using a *NodeId*. Unlike *NodeIds*, the *BrowseName* cannot be used to unambiguously identify a *Node*. Different *Nodes* may have the same *BrowseName*. They are used to build a browse path between two *Nodes* or to define a standard *Property*.

Servers may often choose to use the same namespace for the *NodeId* and the *BrowseName*. However, if they want to provide a standard *Property*, its *BrowseName* shall have the namespace of the standards body although the namespace of the *NodeId* reflects something else, for example the *EngineeringUnits Property*. All *NodeIds* of *Nodes* not defined in this document shall not use the standard namespaces.

Table 6 provides a list of mandatory and optional namespaces used in an OPC 40084-5 OPC UA *Server*.

Table 6 – Namespaces used in an OPC 40084-5 Server

NamespaceURI	Description	Use
http://opcfoundation.org/UA/	Namespace for <i>NodeIds</i> and <i>BrowseNames</i> defined in the OPC UA specification. This namespace shall have namespace index 0.	Mandatory
Local Server URI	Namespace for nodes defined in the local server. This may include types and instances used in a device represented by the server. This namespace shall have namespace index 1.	Mandatory
http://opcfoundation.org/UA/DI/	Namespace for <i>NodeIds</i> and <i>BrowseNames</i> defined in OPC UA Part 100. The namespace index is server specific.	Mandatory
http://opcfoundation.org/UA/PlasticsRubber/GeneralTypes/	Namespace for <i>NodeIds</i> and <i>BrowseNames</i> defined in OPC 40083. The namespace index is server specific.	Mandatory
http://opcfoundation.org/UA/PlasticsRubber/Extrusion/GeneralTypes/	Namespace for <i>NodeIds</i> and <i>BrowseNames</i> defined in OPC 40084-1. The namespace index is server specific.	Mandatory
http://opcfoundation.org/UA/PlasticsRubber/Extrusion/MeltPump/	Namespace for <i>NodeIds</i> and <i>BrowseNames</i> defined in this specification. The namespace index is server specific.	Mandatory
Vendor specific types and instances	A server may provide vendor specific types like types derived from <i>MachineType</i> or <i>MachineStatusType</i> or vendor specific instances of devices in a vendor specific namespace.	Optional

Table 7 provides a list of namespaces and their index used for *BrowseNames* in this specification. The default namespace of this specification is not listed since all *BrowseNames* without prefix use this default namespace.

Table 7 – Namespaces used in this specification

NamespaceURI	Namespace Index	Example
http://opcfoundation.org/UA/	0	0:NodeVersion
http://opcfoundation.org/UA/DI/	2	2:DeviceClass
http://opcfoundation.org/UA/PlasticsRubber/GeneralTypes/	3	3:MachineInformationType
http://opcfoundation.org/UA/PlasticsRubber/Extrusion/GeneralTypes/	4	4:ExtrusionDeviceType

Annex A (normative)

OPC 40084-5 Namespace and mappings

A.1 Namespace and identifiers for OPC 40084-5 Information Model

This appendix defines the numeric identifiers for all of the numeric *NodeIds* defined in this specification. The identifiers are specified in a CSV file with the following syntax:

<SymbolName>, <Identifier>, <NodeClass>

Where the *SymbolName* is either the *BrowseName* of a *Type Node* or the *BrowsePath* for an *Instance Node* that appears in the specification and the *Identifier* is the numeric value for the *NodeId*.

The *BrowsePath* for an *Instance Node* is constructed by appending the *BrowseName* of the instance *Node* to the *BrowseName* for the containing instance or type. An underscore character is used to separate each *BrowseName* in the path. Let's take for example, the *MachineInformationType ObjectType Node* which has the *ControllerName Property*. The **Name** for the *ControllerName InstanceDeclaration* within the *MachineInformationType* declaration is: *MachineInformationType_ControllerName*.

The *NamespaceUri* for all *NodeIds* defined here is <http://opcfoundation.org/UA/PlasticsRubber/Extrusion/MeltPump/>

The CSV released with this version of the specification can be found here:

- <http://www.opcfoundation.org/UA/schemas/PlasticsRubber/Extrusion/MeltPump/1.00/NodeIds.csv>

NOTE: The latest CSV that is compatible with this version of the specification can be found here:

- <http://www.opcfoundation.org/UA/schemas/PlasticsRubber/Extrusion/MeltPump/NodeIds.csv>

A computer processible version of the complete Information Model defined in this specification is also provided. It follows the XML Information Model schema syntax defined in Part 6.

The Information Model Schema released with this version of the specification can be found here:

- <http://www.opcfoundation.org/UA/schemas/PlasticsRubber/Extrusion/MeltPump/1.00/Opc.Ua.PlasticsRubber.Extrusion.MeltPump.NodeSet2.xml>

NOTE: The latest Information Model schema that is compatible with this version of the specification can be found here:

- <http://www.opcfoundation.org/UA/schemas/PlasticsRubber/Extrusion/MeltPump/Opc.Ua.PlasticsRubber.Extrusion.MeltPump.NodeSet2.xml>
-